

EC-TYPE EXAMINATION CERTIFICATE (MODULE B)

Certificate no.:
MEDB0000BZY
Revision no.:
0

Application of: Directive 2014/90/EU of 23 July 2014 on marine equipment (MED), issued as "Forskrift om Skipsutstyr" by the Norwegian Maritime Authority. This Certificate is issued by DNV AS under the authority of the Government of Norway.

This is to certify:

that the **Fire doors**

with type designation(s)
AM B-15 dB(VB-DE) Double Leaf

issued to
Antti-Teollisuus Oy
Kanunki, Finland

is found to comply with the Implementing Regulation (EU) 2025/1533 for
Item no. **MED/3.16 (Row 1 of 1)**
according to the following requirements:
IMO MSC.1/Circ.1511, SOLAS 74 Reg. II-2/9


Further details of the equipment and conditions for certification are given overleaf.

Date of issue: **2026-03-11**

Expiry date: **2031-03-10**

DNV local unit:
Finland CMC

Approval Engineer:
Helge Bjørnarå



Notified Body
no.: **0575**



for **DNV AS**

Digitally Signed By:
Permoda, Jowita
on behalf of

Christine Mydlak-Röder
Head of Notified Body

A U.S. Coast Guard approval number will be assigned to the equipment when the production module has been completed and will appear on the production module certificate (module D, E or F), as allowed by the Agreement between the United States of America and the EEA EFTA states on the mutual recognition of Certificates of Conformity for Marine Equipment signed 17 October 2005, and amended by Decision No 1/2023 dated August 21st, 2023.



The mark of conformity may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity issued when the production-surveillance module (D, E or F) of Annex B of the MED is fully complied with and controlled by a written inspection agreement with a Notified Body. The product liability rests with the manufacturer or his representative in accordance with Directive 2014/90/EU.

This certificate is valid for equipment, which is conform to the approved type. The manufacturer shall inform DNV AS of any changes to the approved equipment. This certificate remains valid unless suspended, withdrawn, recalled or cancelled.

Should the specified regulations or standards be amended during the validity of this certificate, the product is to be re-approved before being placed on board a vessel to which the amended regulations or standards apply.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to USD 300 000.

Product description

"AM B-15 dB(VB-DE) Double Leaf",
a double leaf hinged door with single handle opening. Door leaves consist of 24 mm mineral wool ULTIMATE U SeaProtect Slab 66 (density 66 kg/m³, manufactured by Saint-Gobain Isover) in the middle and 12 mm stone wool Rockwool SeaRox SL488 (density 220 kg/m³, manufactured by Rockwool) on the sides. Insulation is covered with 0.7 mm perforated steel sheets on both sides. The steel sheets are fixed to the insulation with an adhesive.

Total thickness of door leaf: 50 mm.

A top panel of height 252 mm and thickness 73 mm, insulated with mineral wool ULTIMATE U SeaProtect Slab 66 (density 66 kg/m³, manufactured by Saint-Gobain Isover), was placed over the door leaf.

The door frame is made of 1.5 mm steel and fixed to the bulkhead with screws Ø4.8x19 (6 pcs per side). The door leaf is fitted with three hinges. The passive door leaf is locked with BKS shoot bolt system (manufactured by BKS).

The door leaf may be fitted with:

- a mechanical lock Trioiving 5316 (manufactured by Assa Abloy),
- a kick plate with the dimensions of 485 mm x 452 mm (W x H) in the lower part of each door leaf.

For further details, see drawings listed under Type Examination documentation.

Application/Limitation

Approved for use as an integrated part of fire retarding division of class B-15.

Maximum door frame size including top panel: 2080 mm x 2392 mm (W x H).

Maximum door leaf size: 1014 mm x 2115 mm (W x H).

Maximum clear door opening: 2000 mm x 2102 mm (W x H).

The insulation materials and adhesives used have to be approved according to the Marine Equipment Directive and bear the Mark of Conformity. This requirement may also be applicable for surface materials used, if required by relevant rules and regulations.

Each product is to be supplied with its manual for installation, use and maintenance.

Type Examination documentation

Document No.	Rev.	Title
EUF129-25000270-T1		Test report dated 18 December 2025 from Eurofins Expert Services, Espoo, Finland.
D954806	0	Drawing dated 5 November 2025 from manufacturer
D954807	A	Drawing dated 5 November 2025 from manufacturer
D954817	0	Drawing dated 6 November 2025 from manufacturer
D954818	0	Drawing dated 6 November 2025 from manufacturer
D954827	0	Drawing dated 6 November 2025 from manufacturer
D954828	0	Drawing dated 6 November 2025 from manufacturer
D955071	0	Drawing dated 21 November 2025 from manufacturer
D954805	A	Drawing dated 9 March 2026 from manufacturer

Tests carried out

Tested according to IMO 2010 FTP Code part 3.



Certificate no.: **MEDB0000BZY**
Revision no.: **0**

Marking of product

The product is to be marked with name and address of manufacturer, type designation, fire technical rating, the Mark of Conformity and USCG Approval Number if applicable (see first page).